PLUMBING FIXTURE SCHEDULE

[1. FIXTURES LISTED BELOW ARE SUBJECT TO OWNER AND/OR ARCH. APPROVAL.] - [2. REFER TO ARCHITECTURAL DRAWINGS FOR ALL MOUNTING HEIGHTS.]

TAG	FIXTURE NAME	PROVIDE THE FOLLOWING SIZE BRANCH CONNECTION TO THE DISTRIBUTION MAIN - UNLESS OTHER WISE SPECIFIED					MAKE, MODEL AND DESCRIPTION
		TRAP	WASTE	VENT	CW	HW	
SK-2	THREE COMPARTMENT SINK	1 1/2"	3" AIR GAP TO FS-X	2"	1/2"	1/2"	93-3-54-18R/L REGALINE16 GAUGE 304 STAINLES STEEL THREE COMPARTMENT SINKWITH 8" HIGH SPLASH PROTECTIONONE PIECE DEEP DRAWN SINK BOWL WITH ROUNDED INTERNAL CORNERS (16"WX20"LX12"D), AND INTEGRAL 18" DRAIN BOARD WITH SPLASH. KEYHOLE WALL MOUNT BRACKET, STAINLESS STEEL BASKET DRAIN 1 1/2"IPS, 4"O.C. SPLASH MOUNTED GOOSENECK FAUCET, CHROME PLATED FURNISHED WITH AERATOR. 2165 MCGUIRE ANGLE SUPPLY/WHEEL HANDLE. 8872 MCGUIRE CAST BODY P-TRAP AND CLEANOUT. INSULATE P-TRAP, TAILPIECE ASSEMBLY, AND HOT AND COLD WATER ANGLE VALVES WITH BROCAR PRODUCTS, INC. TRAP WRAP.
SK-3	DOUBLE BOWL SINK	1 1/2"	2"	2"	1/2"	1/2"	LRAD291855 ELKAY, DOUBLE BOWL (29"L X 18"W X 5 1/2"D INSIDE BOWL), #20 GAUGE TYPE 304 NICKEL BEARING STAINLESS STEEL, SELF RIMMING, 3 HOLE 8" FIXED CENTERS. 110-GN8AE3 CHICAGO FAUCETS, [1.5GPM]
TMV	THERMOSTATIC MIXING VALVE	-	-	-	3/8"	3/8"	LF-170 LEONARD, THERMOSTATIC MIXING VALVE WITH THE OUTLET TEMPERATURE TO BE SET AT 105°F. TMV SHALL COMPLY WITH ASSE 1070 & 1017. INLETS AND OUTLETS SHALL BE 3/8". LK99 ELKAY, TYPE 304 STAINLESS STEEL BODY AND REMOVABLE CONICAL BASKET STRAINER WITH METAL BALL BEARING LOCKING STEM AND RUBBER STOPPER, FITS 3-1/2" (89MM) OPENING, ULTRA BRIGHT POLISHED FINISH, TYPE 304 STAINLESS STEEL 1-1/2" (38MM) X 4" (102MM) TAILPIECE. 1151WC MCGUIRE 1 1/2" ADA COMPLIANT OFFSET STAINER/DRAIN ASSEMBLY AND TAILPIECE, C8912 MCGUIRE 1 1/2" CAST BODY P-TRAP AND CLEANOUT. INSULATE P-TRAP, TAILPIECE ASSEMBLY. BV2165 MCGUIRE QUARTER-TURN BRASS BALL VALVE, CONVERTIBLE LOOSE KEY HANDLE, 1/2" I.P.S. X 3/4" O.D.
HS-1	HAND SINK	1 1/2"	3"	2"	1/2"	1/2"	7-PS-60 ADVANCE TABCO [1.5GPM] WALL MOUNTED HAND SINK, ONE PIECE DEEP DRAWN SINK BOWL (10"WX14"LX8"D), KEYHOLE WALL MOUNT BRACKET, STAINLESS STEEL BASKET DRAIN 1 1/2"IPS, 4"O.C. SPLASH MOUNTED GOOSENECK FAUCET, CHROME PLATED FURNISHED WITH AERATOR. 2165 MCGUIRE ANGLE SUPPLY/WHEEL HANDLE. 8872 MCGUIRE CAST BODY P-TRAP AND CLEANOUT. INSULATE P-TRAP, TAILPIECE ASSEMBLY, AND HOT AND COLD WATER ANGLE VALVES WITH BROCAR PRODUCTS, INC. TRAP WRAP.
MS-1	MOP SINK	3"	3"	2"	3/4"	3/4"	TDF-24-SSC ACORN 24"X24"X12" HEIGHT DROP FRONT TERRAZZO MOP SINK, PROVIDE AND INSTALL AN ACORN DROP FRONT MOP SINK. MOP SINK SHALL BE MADE OF PRECAST TERRAZZO TO PRODUCE A COMPRESSIVE STRENGTH OF AT LEAST 3,000 PSI SEVEN DAYS AFTER CASTING. ALL EXPOSED SURFACES SHALL BE GROUND SMOOTH AND SEALED. NO AIR HOLES OR PITS SHALL BE ALLOWED ON THE FINISHED SURFACE. SINK SHALL HAVE COVED CORNERS AND BE PITCHED TO THE DRAIN OUTLET FOR POSITIVE DRAINAGE. INTEGRAL DRAIN SHALL HAVE A STAINLESS STEEL STRAINER AND PROVIDE FOR AN INSIDE CAULKED CONNECTION TO A 3" PIPE. THE MANUFACTURER WILL PROVIDE TO THE INSTALLER THE NECESSARY INSTALLATION INSTRUCTIONS. PROVIDE: A. MOP-SERVICE SINK FITTING WITH VACUUM BREAKER, ADJUSTABLE TOP BRACE, 3/4" HOSE THREAD ON SPOUT WITH BUCKET HOOK INLETS 8" ON CENTER, CHROME FINISH. B. HOSE AND WALL HOOK. HOSE 36" LONG, WITH 3/4" CHROME COUPLINGS. WALL BRACKET OF STAINLESS STEEL. C. STAINLESS STEEL MOP HANGER OF STAINLESS STEEL WITH #4 FINISH. . . 24" LONG, WITH 3 RUBBER SPRING LOADED GRIPS. D. SPLASH CATCHER PANELS OF 20 GA. TYPE 304 STAINLESS STEEL.
WH-1	WALL HYDRANT [NON-FREEZE]	-	-	-	3/4"	-	Z1300 ZRUN ENCASED ECOLOTROL "ANTI-SIPHON" AUTOMATIC DRAINING WALL HYDRANT FOR FLUSH INSTALLATION. COMPLETE WITH NON-FREEZE TYPE INTEGRAL BACKFLOW PREVENTER, BRONZE CASING, ALL BRONZE INTERIOR PARTS, NON-TURNING OPERATING ROD WITH FREE-FLOATING COMPRESSION CLOSURE VALVE, REPLACEABLE BRONZE SEAT AND SEAT WASHER, AND COMBINATION 3/4" FEMALE OR 1" MALE STRAIGHT IP INLET. NICKEL BRONZE BOX AND HINGED COVER WITH OPERATING KEY LOCK AND "WATER" CAST ON COVER.
WH-2	WALL HYDRANT [NARROW WALL]	-	-	-	3/4"	-	5518 J R SMITH, ALL BRONZE WARM CLIMATE HYDRANT WITH CHROME PLATED FACE, HOSE CONNECTION HAVING INTEGRAL ASSE 1011 VACUUM BREAKER, 360 SWIVEL INLET CONNECTION, "T" HANDLE KEY AND STAINLESS STEEL BOX.
FCO-1	FLOOR CLEAN OUT [WITH-IN BUILDING]	-	3"-6"	-	-	-	ZURN Z1400-SZ1 CLEANOUT, DURA-COATED CAST IRON BODY WITH BOTTOM OUTLET, INSTALLATION AND COMPRISED OF CONCRETE SHIELD TO PROVIDE UP TO 1-1/4" OF VERTICAL POST POUR ADJUSTMENT, PRE-PACKAGED SHIMS FOR TILT CORRECTION, AND INTEGRATED, SELF-CONTAINED "TYPE S" LIGHT DUTY SCORIATED COVER WITH ROUGH-IN COVER FOR PROTECTION DURING CONCRETE POUR. CLEANOUT SHALL BE DESIGNED IN ACCORDANCE WITH ASME A112.36.2M.
ECO-1	EXTERIOR FLOOR CLEAN OUT [OUTSIDE BUILDING]	-	4"-6"	-	-	-	Z1400 ZURN, EXTRA HEAVY DUTY ADJUSTABLE FLOOR CLEANOUT, DURA-COATED CAST IRON BODY WITH POLISHED BRONZE, NICKEL BRONZE, AND STAINLESS STEEL TOP OPTIONS COMPATIBLE WITH INSIDE CAULK, NO-HUB AND NEO-LOC CONNECTION TYPES ADJUSTABLE TYPE, EXTRA HEAVY-DUTY CLEANOUT. WHEN INSTALLING IN GRASSY AREA AND ASPHALT PAVEMENT INSTALL WITH IN A 24"X24"X12" DEEP CONCRETE.[DO NOT INSTALL THIS CLEANOUT IN DRIVE WAYS]
WCO-1	WALL CLEAN OUT	-	2"-6"	-	-	-	Z1445 ZURN, CLEANOUT TEE. DURA-COATED CAST IRON BODY WITH GAS AND WATERTIGHT ABS TAPERED THREAD PLUG. [MEANT FOR SANITARY LINES SERVING UPPER FLOORS] [IF USSED FOR ONLY WALL CLEAN OUT CAP AND SEAL 6" ABOVE CLEANOUT.] CLEAN OUT SHALL BE INSTALLED IN AN ARCHITECT / OWNER APPROVED LOCATION. MOUNT ALL WALL CLEANOUTS AT 36" A.F.F. AND 12" AWAY FROM ALL WALLS.
FD-1	FLOOR DRAIN [FLOOR & SHOWER]	3"-4"	3"-4"	2"	-	-	Z415-B ZURN FLOOR AND SHOWER DRAIN, DURA-COATED CAST IRON BODY WITH BOTTOM OUTLET, COMBINATION INVERTIBLE MEMBRANE CLAMP AND ADJUSTABLE COLLAR WITH SEEPAGE SLOTS AND TOP ASSEMBLY. COMPRISED OF CONCRETE SHIELD, UP TO 1-1/4" OF VERTICAL POST POUR ADJUSTMENT, PRE-PACKAGED SHIMS FOR TILT CORRECTION AND INTEGRATED, SELF-CONTAINED "TYPE B" LIGHT DUTY STRAINER WITH ROUGH-IN COVER FOR PROTECTION DURING CONCRETE POUR.
FD-2	FLOOR DRAIN [KITCHEN]	3"-4"	3"-4"	2"	-	-	Z415-B-AR ZURN AREA FLOOR DRAIN, W/ ACID RESISTING EPOXY COATED CAST IRON BODY WITH BOTTOM OUTLET, COMBINATION INVERTIBLE MEMBRANE CLAMP AND ADJUSTABLE COLLAR WITH SEEPAGE SLOTS AND TOP ASSEMBLY. COMPRISED OF CONCRETE SHIELD, UP TO 1-1/4" OF VERTICAL POST POUR ADJUSTMENT, PRE-PACKAGED SHIMS FOR TILT CORRECTION AND INTEGRATED, SELF-CONTAINED "TYPE B" LIGHT DUTY STRAINER WITH ROUGH-IN COVER FOR PROTECTION DURING CONCRETE POUR.
FS-1	FLOOR SINK [MECH. ROOM]	3"-6"	3"-6"	2"	-	-	Z1751 ZURN, 12" X 12" X 8" DEEP, 16 GAGE, ALL TYPE 304 (CF8) STAINLESS STEEL LIGHT-DUTY SANI-FLOR RECEPTOR WITH NON-TILT, LOOSE SET FULL GRATE WITH 1/2" [13MM] SQUARE OPENINGS AND ANTI-SPLASH STAINLESS STEEL INTERIOR DOME STRAINER. STAINLESS STEEL GRATE.
FS-2	FLOOR SINK [KITCHEN]	4"	4"	2"	-	-	Z1900- ZURN, SANI-FLOR RECEPTOR 12" X 12" X 6" DEEP CAST IRON BODY, AND SQUARE, LIGHT-DUTY GRATE WITH 1/2" SLOTTED OPENINGS, WHITE ACID RESISTING PORCELAIN ENAMEL INTERIOR AND TOP, COMPLETE WITH WHITE ABS ANTI-SPLASH INTERIOR BOTTOM DOME STRAINER. STAINLESS STEEL GRATE [IF BELOW EQUIPMENT 3/4 GRATE IF IN OPEN SPACE FULL GRATE.]

PLUMBING FIXTURE SCHEDULE

[1. FIXTURES LISTED BELOW ARE SUBJECT TO OWNER AND/OR ARCH. APPROVAL.] - [2. REFER TO ARCHITECTURAL DRAWINGS FOR ALL MOUNTING HEIGHTS.]

TAG	FIXTURE NAME	PROVIDE THE FOLLOWING SIZE BRANCH CONNECTION TO THE DISTRIBUTION MAIN - UNLESS OTHER WISE SPECIFIED					MAKE, MODEL AND DESCRIPTION
		TRAP	WASTE	VENT	CW	HW	
WC-1	WATER CLOSET (FLOOR MOUNTED)	INT.	4"	2"	1"	-	2234.001 AMERICAN STANDARD "MADERA", FLOOR MOUNTED, 14"HIGH, ELONGATED BOWL, WITH 1-1/2 INCH INLET TOP SPUD. 111-1.6 SLOAN ROYAL FLUSH VALVE WITH VACUUM BREAKER, AND 1-INCH SCREWDRIVER ANGLE STOP. 111-1.28-ES-S-TMO SLOAN "OPTIMA", [1.28 GPF], 1" I.P.S. SCREWDRIVER BAK-CHEK® ANGLE STOP, FREE SPINNING VANDAL RESISTANT STOP CAP, HIGH BACK PRESSURE VACUUM BREAKER FLUSH CONNECTION WITH ONE-PIECE BOTTOM HEX COUPLING NUT, SPUD COUPLING AND FLANGE FOR 1 ½" TOP SPUD, EL-154 TRANSFORMER (120 VAC/24 VAC 50 VA). THE PLUMBING CONTRACTOR IS RESPONSIBLE FOR THE CONCEALED LOW VOLTAGE WIRING BETWEEN THE MULTI USE TRANSFORMER FOR THE WATER CLOSETS, URINALS AND FACULTY LAVATORIES. LOCATE THE TRANSFORMERS ABOVE ACCESSIBLE CEILINGS OR PROVIDE ACCESS PANEL FOR HARD CEILINGS. UP TO 6 FIXTURE PER TRANSFORMER. 9500C CHURCH, ELONGATED SEAT, OPEN FRONT LESS COVER, SOLID PLASTIC, CONCEALED CHECK STAINLESS STEEL HINGES.
WC-2	WATER CLOSET (FLOOR MOUNTED) (A.D.A.)	INT.	4"	2"	1"	-	3043.001 AMERICAN STANDARD "MADERA", ADA 17"H ELONGATED BOWL, WITH 1-1/2 INCH INLET SPUD. 111-1.28-ES-S-TMO SLOAN "OPTIMA", [1.28 GPF], 1" I.P.S. SCREWDRIVER BAK-CHEK® ANGLE STOP, FREE SPINNING VANDAL RESISTANT STOP CAP, HIGH BACK PRESSURE VACUUM BREAKER FLUSH CONNECTION WITH ONE-PIECE BOTTOM HEX COUPLING NUT, SPUD COUPLING AND FLANGE FOR 1 ½" TOP SPUD, EL-154 TRANSFORMER (120 VAC/24 VAC 50 VA).THE PLUMBING CONTRACTOR IS RESPONSIBLE FOR THE CONCEALED LOW VOLTAGE WIRING BETWEEN THE MULTI USE TRANSFORMER FOR THE WATER CLOSETS, URINALS AND FACULTY LAVATORIES. LOCATE THE TRANSFORMERS ABOVE ACCESSIBLE CEILINGS OR PROVIDE ACCESS PANEL FOR HARD CEILINGS. UP TO 6 FIXTURE PER TRANSFORMER. 9500C CHURCH, ELONGATED SEAT, OPEN FRONT LESS COVER, SOLID PLASTIC, CONCEALED CHECK STAINLESS STEEL HINGES.
WC-3	WATER CLOSET [PRE-K TOILETS] (FLOOR MOUNTED)	INT.	4"	2"	1"	-	2282.001 AMERICAN STANDARD "BABY DEVORO", [1.28 GPF], WITH 1-1/2 INCH INLET SPUD. 111-1.28-ES-S-TMO SLOAN "OPTIMA", [1.28 GPF], 1" I.P.S. SCREWDRIVER BAK-CHEK® ANGLE STOP, FREE SPINNING VANDAL RESISTANT STOP CAP, HIGH BACK PRESSURE VACUUM BREAKER FLUSH CONNECTION WITH ONE-PIECE BOTTOM HEX COUPLING NUT, SPUD COUPLING AND FLANGE FOR 1 ½" TOP SPUD, EL-154 TRANSFORMER (120 VAC/24 VAC 50 VA).THE PLUMBING CONTRACTOR IS RESPONSIBLE FOR THE CONCEALED LOW VOLTAGE WIRING BETWEEN THE MULTI USE TRANSFORMER FOR THE WATER CLOSETS, URINALS AND FACULTY LAVATORIES. LOCATE THE TRANSFORMERS ABOVE ACCESSIBLE CEILINGS OR PROVIDE ACCESS PANEL FOR HARD CEILINGS. UP TO 6 FIXTURE PER TRANSFORMER. 5001G.055 AMERICAN STANDARD, BABY DEVORO, OPEN FRONT. BV02 MCGUIRE, 1/2 IPS X 3/8 OD, QUARTER-TURN BRASS BALL VALVE ANGLE STOP, CHROME PLATED, CONVERTIBLE LOOSE KEY HANDLE. SUPPLY STOP VALVE SHALL BE CERTIFIED BY CSA OR OTHER RECOGNIZED TESTING AUTHORITY AND SHALL BEAR MANUFACTURER AND TESTING MARK. STOP TO BE CERTIFIED TO 200 PSI LINE PRESSURE.
WC-4	WATER CLOSET [3RD FLOOR ONLY] [TANK] [FACULTY RR] (FLOOR MOUNTED) (A.D.A.)	INT.	4"	2"	1/2"	-	270AA.101 AMERICAN STANDARD "CADET SUITE", [1.28 GPF], FEATURES THE CADET® FLUSHING SYSTEM, VITREOUS CHINA, HIGH EFFICIENCY TOILET (HET), ULTRA-LOW CONSUMPTION, INCLUDES COLOR MATCH BOWL CAPS, 3" FLUSH VALVE, 2-1/8" TRAPWAY, 16-1/2" RIM HEIGHT FOR ACCESSIBLE APPLICATIONS, 12" ROUGH-IN, GENEROUS 9" X 8" WATER SURFACE AREA, CHROME FINISH TRIP LEVER IS SUPPLIED, 1,000G MAP SCORE** AT 1.28 GPF. 9500CT CHURCH, EXTRA HEAVY WEIGHT AND INJECTION MOLDED OF SOLID PLASTIC, OPEN FRONT LESS COVER FOR ELONGATED BOWL AND FEATURE LARGE MOLDED-IN BUMPERS. CONCEALED CHECK HINGES TO FEATURE 300 SERIES STAINLESS STEEL POSTS THAT STOP SEAT 11 DEGREES BEYOND VERTICAL. USES 300 SERIES STAINLESS STEEL HARDWARE. BV02 MCGUIRE, 1/2 IPS X 3/8 OD, QUARTER-TURN BRASS BALL VALVE ANGLE STOP, CHROME PLATED, CONVERTIBLE LOOSE KEY HANDLE. SUPPLY STOP VALVE SHALL BE CERTIFIED BY CSA OR OTHER RECOGNIZED TESTING AUTHORITY AND SHALL BEAR MANUFACTURER AND TESTING MARK. STOP TO BE CERTIFIED TO 200 PSI LINE PRESSURE.
WC-5	WATER CLOSET [3RD FLOOR ONLY] [TANK] [PRE-K TOILETS] (FLOOR MOUNTED)	INT.	4"	2"	1/2"	-	2315.228 AMERICAN STANDARD "CADET SUITE", [1.28 GPF], VITREOUS CHIVA, 10" ROUGHING-IN, ROUND FRONT SIPHON ACTION BOWL, CHROME TRIP LEAVER, FULLY GLAZED TRAPWAY, 5001G.055 AMERICAN STANDARD, BABY DEVORO, OPEN FRONT. BV02 MCGUIRE, 1/2 IPS X 3/8 OD, QUARTER-TURN BRASS BALL VALVE ANGLE STOP, CHROME PLATED, CONVERTIBLE LOOSE KEY HANDLE. SUPPLY STOP VALVE SHALL BE CERTIFIED BY CSA OR OTHER RECOGNIZED TESTING AUTHORITY AND SHALL BEAR MANUFACTURER AND TESTING MARK. STOP TO BE CERTIFIED TO 200 PSI LINE PRESSURE.
EDF-1	ELEC. DRINKING FOUNTAIN W/ BOTTLE FILL. A.D.A.	1 1/2"	2"	2"	1/2"	-	LZS8WSLK ELKAY, BOTTLE FILLING STATION WITH SINGLE ADA COOLER, FILTERED 8 GPH LIGHT GRAY. CHILLING CAPACITY OF 8.0 GPH (GALLONS PER HOUR) OF 50 DEG. F. DRINKING WATER, BASED ON 80 DEG. F. INLET WATER AND 90 DEG. F. AMBIENT, PER ASHRAE 18 TESTING. FEATURES SHALL INCLUDE HANDS FREE, VISUAL FILTER MONITOR, FILTERED, FURNISHED WITH SAFETY BUBBLER. ELECTRONIC BOTTLE FILLER SENSOR WITH ELECTRONIC FRONT AND SIDE BUBBLER PUSHBAR ACTIVATION. PRODUCT SHALL BE WALL MOUNT, FOR INDOOR APPLICATIONS. FIED TO NSF/ANSI 61 & 372 (LEAD FREE) AND MEETS FEDERAL AND STATE LOW-LEAD REQUIREMENTS. **CONTRACTOR SHALL PROVIDE CLIENT WITH TWO SETS OF WSF6000R-2PK - WATERSENTRY PLUS 51300C FILTER - REPLACEMENT (2PACK) TO BE HANDED OVER TO THE OWNER.** **LKAPREZL ELKAY**- CANE APRON FOR SWIRLFLO. 2165LK MCGUIRE 1/2" X 3/8" ANGLE STOP AND SUPPLY-LOOSE KEY. C8912 MCGUIRE, 1-1/4" O.D. - 1-1/2" O.D. CAST BODY P-TRAP WITH CLEANOUT. PROVIDE WITH IN WALL CARRIER MOUNTING SYSTEM. REFER TO ARCHITECT FOR ALL MOUINTING HEIGHTS
SK-1	SINK	1 1/2"	2"	2"	1/2"	1/2"	LRAD1918 ELKAY, SINGLE BOWL (19"L X 18"W X 6"D INSIDE BOWL), #20 GAUGE TYPE 304 NICKEL BEARING STAINLESS STEEL, SELF RIMMING, 3 HOLE 8" FIXED CENTERS. 201-AGN8AE36-317AB CHICAGO FAUCETS[1.5GPM] 8" FIXED CENTERS, 8" RIGID / SWING GOOSENECK SPOUT, NON-AERATING LAMINAR OUTLET, 4" VANDAL PROOF WRISTBLADE HANDLE, QUATURN COMPRESSION OPERATING CARTRIDGE, 1/2" NPSM SUPPLY INLETS AND COUPLING NUT FOR 3/8" OR 1/2" FLEXIBLE RISER, DURABLE BRASS LEAD FREE OR LESS THAN 0.25% BY WEIGHTED AVERAGE.
TMV	THERMOSTATIC MIXING VALVE	-	-	-	3/8"	3/8"	LF-170 LEONARD, THERMOSTATIC MIXING VALVE WITH THE OUTLET TEMPERATURE TO BE SET AT 105°F. TMV SHALL COMPLY WITH ASSE 1070. LK99 ELKAY, TYPE 304 STAINLESS STEEL BODY AND REMOVABLE CONICAL BASKET STRAINER WITH METAL BALL BEARING LOCKING STEM AND RUBBER STOPPER, FITS 3-1/2" (89MM) OPENING, ULTRA BRIGHT POLISHED FINISH, TYPE 304 STAINLESS STEEL 1-1/2" (38MM) X 4" (102MM) TAILPIECE. 1151WC MCGUIRE 1 1/2" ADA COMPLIANT OFFSET STAINER/DRAIN ASSEMBLY AND TAILPIECE, C8912 MCGUIRE 1 1/2" CAST BODY P-TRAP AND CLEANOUT. INSULATE P-TRAP, TAILPIECE ASSEMBLY. REFER TO MECH PLANS FOR USE OF CONDENSATE P-TRAP THIS SHALL REPLACE THE ABOVE IF REQUIRED BY MECH DRAWINGS. [JAY R. SMITH MODEL 9200 P-TRAP] BV2165 MCGUIRE QUARTER-TURN BRASS BALL VALVE, CONVERTIBLE LOOSE KEY HANDLE, 1/2" I.P.S. X 3/4" O.D.

NOTES: LAVATORIES ARE ON NEXT PAGE

O 281 410 1349
www.wsquaredarch.com

w [squared] architects

GK ENGINEERS
GK ENGINEERS, LLC
TEXAS-REG # F-18854
5959 W. LOOP SOUTH, SUITE 385
BELLAIRE, TX 77096
PH: 832.250.1966
PH: 713.208.0964

ISSUES AND REVISIONS

NO	DATE	DESCRIPTION
A	07-22-2019	ISSUED FOR PERMIT
B	08-16-2019	ISSUED FOR BID

STATE OF TEXAS
DAVIA ANN GERNAND
109903
LICENSED
PROFESSIONAL ENGINEER
16 AUG 2019

GH SCHOOL
4724 N MAIN STREET

SHEET TITLE
SCHEDULES

SHEET NUMBER
P101

PROJECT # 19.02

©2019 W SQUARED DESIGN, INC.
Architect shall own the overall conceptual design prepared and developed for the project on the intangible exclusive rights or copyright therein.

C:\Users\wjklu\Documents\1902-GHS-190517-MODEL_R18_GK_MEP-Latest_Chris.Tuey.rvt
8/19/2019 5:04:39 PM